

Approval Number: 1508543  
Test Report: M105981 A&B



Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

25<sup>th</sup> July 2017

Francesco Franceschetti Elastomeri Srl.  
Via G. Pastore 33/35,  
25040 Corte Franca,  
Brescia,  
Italy

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**THERMOPLASTIC ELASTOMER - MATERIAL ONLY**

**5586**

'Marfran E DRW OF 050A & Marfran E DRW OF 090A'. Natural (pale straw) coloured, injection moulded thermoplastic elastomeric materials. Shore hardness 50 & 90. Tested in-radius size 1.1mm. For use with water up to 60°C.

**APPROVAL NUMBER: 1508543**

**APPROVAL HOLDER: FRANCESCO FRANCESCHETTI ELASTOMERI SRL.**

The Scheme reserves the right to review approval.  
Approval 1508543 is valid between August 2015 and August 2020

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme